



SEE NOTES ON SHEET 2

CITY OF MISSION VIEJO

PARKWAY OBSTRUCTIONS

STANDARD
PLAN NO.

324



APPROVED

RCE 30190

DATE

Robert Anderson

9-23-03

SHT 1 OF 2

NOTES:

1. THE DISTANCE FROM THE CURB TO ANY PART OF A FIRE HYDRANT SHALL BE NOT LESS THAN TWO (2) FEET NOR GREATER THAN SEVEN (7) FEET.
2. FOR ANY VERTICAL OBSTRUCTION, THE MINIMUM CLEARANCE FROM THE CURB SHALL BE 1'-6".
3. THE MINIMUM WIDTH OF CLEAR SIDEWALK AREA SHALL BE FOUR (4) FEET FROM ANY VERTICAL OBSTRUCTION.
4. ANY UTILITY VAULT WITHIN THE SIDEWALK AREA SHALL HAVE A BOLT DOWN COVER WITH A SLIP RESISTANT FINISH.
5. ANY PARKWAY OBSTRUCTION SHALL BE SURROUNDED BY A CONCRETE PAD.
6. REFER TO STD. PLAN 321 FOR SIDEWALK CONSTRUCTION.

CITY OF MISSION VIEJO



PARKWAY OBSTRUCTIONS

STANDARD
PLAN NO.

324

Robert Anderson 9-23-03

APPROVED RCE 30190 DATE

SHT 2 OF 2